

YTELSESERKLÆRINGEN


Nr NEXA13319-CPR-01

1. Varetypens unike identifikasjonskode: **NEXA-101LC**
2. Tilsiktet bruksområde: **Røykvarsler for hjemmebruk**
3. Produsent: **Nexa Trading AB, Box 12200, SE-402 42 Göteborg, Sverige Vat.nr: SE556327631901**
4. System eller systemer for vurdering og verifikasjon av byggevarers ytelser: **System 1**
5. Harmonisert produktstandard: **EN 14604:2005/AC:2008**
6. Teknisk(e) kontrollorgan: : **BRE Global Limited 0832 har utstedte sertifikater 0832-CPR-F1068**
7. Angiven prestanda: **Optisk røykvarslere for seriekobling**
8. Bruk av hensiktsmessig teknisk dokumentasjon og/eller spesifikk teknisk dokumentasjon:

Väsentlig egenskap	Prestanda	Harmonisert teknisk standard
Nominal activation conditions/ Sensitivity, Response delay (response time) and Performance under fire Condition	Pass	EN14604:2005/ AC:2008
Operational reliability	Pass	
Tolerance to supply voltage	Pass	
Durability of operational reliability and response delay, temperature resistance	Pass	
Durability of operational reliability, vibration resistance	Pass	
Durability of operational reliability, humidity resistance	Pass	
Durability of operational reliability, corrosion resistance	Pass	
Durability of operational reliability, electrical stability	Pass	

Ytelser for denne byggevaren, som er anført ovenfor, er i overensstemmelse med de angitte ytelsene. Denne ytelseserklæringen er utarbeidet i overensstemmelse med forordning (EU) nr. 305/2011 under eneansvar til produsenten, som er anført ovenfor.

Underskrevet for produsenten og på denne vegne av:



Erik Hjelmström

VD

Göteborg 2015-08-17